

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No. : TR/WTL/PHD/PWD/PDY/2026/W-0231

Date: 29.06.2026

TEST REPORT - CHEMICAL

Customer Name & Address : Vaasavi International School (CBSE),
No.401, M.G.Road, Muthialpet, Puducherry - 605003.
Customer Reference : Letter No.VIS/CBSE/2026-27/06/002, dt.23.06.2026

Page 1 of 1

SAMPLE DETAILS


Sample Code	: 2026/W-0231	Information provided by the Customer	
Product Category	: Water	Sampled on	: 23.06.2026
Sample Name	: Drinking Water	Sample Description	: Treated Water
Sample Condition	: Fit for analysis	Sample Source	: --
Sampled by	: Customer	Identification by Customer	: Sample - V
Sample Received on	: 23.06.2026	Sampling Location	: School Campus, No.401, M.G.Road, Muthialpet, Puducherry.
Test Started on	: 23.06.2026		
Test Completed on	: 29.06.2026		

TEST RESULTS

CHEMICAL REPORT

Test Parameter	Test Method	Units	Results	Drinking water standard as per IS 10500-2012	
				Acceptable Limit (Requirement)	Permissible limit in the absence of alternate Source
Table 1 General Parameters Concerning Substances Undesirable in Excessive Amounts					
pH @ 25°C	APHA, 24th Edition, 2023, 4500-H+B	--	6.19	6.5 to 8.5	No relaxation
Electrical Conductivity @ 25°C	APHA, 24th Edition, 2023, 2510 B	µs/cm	109	---	---
Total Dissolved Solids	PWDWTL/SOP/08/Issue No.01/dt.23.9.16	mg/L	67.6	500 Max	2000 Max
Table 2 General Parameters Concerning Substances Undesirable in Excessive Amounts					
Total Alkalinity as CaCO ₃	APHA, 24th Edition, 2023, 2320 B	mg/L	15.2	200 Max	600 Max
Total Hardness as CaCO ₃	APHA, 24th Edition, 2023, 2340 C	mg/L	12.3	200 Max	600 Max
Calcium as Ca	APHA, 24th Edition, 2023, 3500-Ca B	mg/L	2.77	75 Max	200 Max
Magnesium as Mg	APHA, 24th Edition, 2023, 3500-Mg B	mg/L	<2.0	30 Max	100 Max
Iron as Fe	APHA, 24th Edition, 2023, 3500 Fe B	mg/L	<0.10	1.0 Max	No Relaxation
Chloride as Cl	APHA, 24th Edition, 2023, 4500-Cl B	mg/L	21.9	250 Max	1000 Max
Sulphate as SO ₄	APHA, 24th Edition, 2023, 4500-SO4 E	mg/L	<5.00	200 Max	400 Max
Nitrate as NO ₃	APHA, 24th Edition, 2023, 4500-NO ₃ B	mg/L	<5.00	45 Max	No Relaxation
Fluoride as F	APHA, 24th Edition, 2023, 4500-F C	mg/L	<0.10	1.0 Max	1.5 Max

.....End of Report.....


N. Annamalai
(Technical Manager)

Copy submitted to:
The Executive Engineer,
PHD., PWD., Puducherry.


SHRI. M. MARIMUTHU
PRINCIPAL
VAASAVI INTERNATIONAL SCHOOL
401, M.G. Road, Muthialpet
Puducherry - 605 003


P. VENUGOPAL
CHAIRMAN
VAASAVI INTERNATIONAL SCHOOL
401, M.G. Road, Muthialpet
Puducherry - 605 003

Terms and Conditions:

1. The test result relevant only to the item tested.
2. The tested report shall not be reproduced in full or part without written approval of WTL-PHDPWD.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory is not responsible for any legal dispute that may arise in future if the sample was not drawn by the laboratory personnel.

**GOVERNMENT OF PUDUCHERRY
WATER TESTING LABORATORY
P.H.D., P.W.D., PUDUCHERRY**

Report No. : TR/WTL/PHD/PWD/PDY/2026/B-0018

Date: 25.06.2026

TEST REPORT

Page 1 of 1

Customer Name & Address : Vaasavi International School (CBSE),
No.401, M.G.Road, Muthialpet, Puducherry - 605003.
Customer Reference : Letter No.VIS/CBSE/2026-27/06/004, dt.23.06.2026

SAMPLE DETAILS

Sample Name	: Water	Sampled by	: Customer
Sample Description	: Drinking Water	Sampled on	: 22.06.2026
Identification by customer	: Sample 1	Sampling Procedure	: --
Sample Condition	: Fit for analysis	Sample Received on	: 22.06.2026
Test Started on	: 23.06.2026	Test Completed on	: 25.06.2026


TEST RESULTS

Sl.No.	Sample Code	Location (Customer site)	Total Coliform	Feacal Coliform
			<-----MPN INDEX----->	
			WHO GUIDELINES for Drinking Water Quality - Vol-3	
1	2026/B-0018	School Campus, No.401, M.G.Road, Muthialpet, Puducherry.	Absent	Absent


Remarks:

The water sample meets the requirement of the standards in respect of the above parameters analysed.

.....End of Report.....


N. Annamalai
(Technical Manager)


SHRI. M. MARIMUTHU
PRINCIPAL
VAASAVI INTERNATIONAL SCHOOL
401, M.G. Road, Muthialpet
Puducherry - 605 003


P. VENUGOPAL
CHAIRMAN
VAASAVI INTERNATIONAL SCHOOL
401, M.G. Road, Muthialpet
Puducherry - 605 003

Copy Submitted to:
The Executive Engineer,